



NOTES

1. RESIDENTIAL DRAINAGE CONNECTIONS SHOULD BE 100mm DIA.
2. UNIT OR INDUSTRIAL DRAINAGE CONNECTIONS TO BE 150mm DIA.
3. PIPES AND FITTINGS TO BE U.P.V.C., AND MEET AS 1260 CLASS SN8 (OR ALTERNATIVELY SN10)
4. ALL JOINTS TO BE SOLVENT WELDED WITH APPROVED SOLVENT.
5. STEP IRONS TO BE PROVIDED IN ALL PITS OVER 900mm DEEP. SEE SD 228



GREATER DANDENONG

PROPERTY DRAIN CONNECTION
 TYPE 4 – CONNECTION TO DRAINAGE PIT

LAST UPDATED – MARCH 2015

INFRASTRUCTURE PLANNING

SD 504-B