



PIPE BEDDING DETAIL

SCALE 1:10

REFER TO THE RELEVANT SECTION OF THE CITY OF GREATER DANDENONG ENGINEERING CONSTRUCTION SPECIFICATION FOR COMPACTION REQUIREMENTS OF THE ABOVE ELEMENTS

NOTES

1. ALL TRENCHES UNDER KERB AND CHANNEL, DRIVEWAYS, FOOTPATHS AND ROAD PAVEMENT SHOULD BE BACKFILLED AS PER STANDARD SPECIFICATION.
2. ALL 150 PIPES TO BE PVC (SH), 225 TO BE PVC (SH) OR RRJ R.C./FRC, ALL PIPE SIZES TO BE RUBBER RING JOINTED (RRJ)
3. ALL R.C./ F.R.C. PIPES TO BE CLASS 2 UNLESS SPECIFIED DIFFERENTLY.
4. EASEMENT DRAINS TO BE LOCATED TO ENSURE 500mm MINIMUM FROM EDGE OF PIPE TO EDGE OF EASEMENT. REINSTATEMENT WORKS REFER TO NOTE 1.
5. IF TRENCH IS WITHIN 150mm OF KERB THEN TRENCH IS TO BE BACKFILLED WITH SELECT BACKFILL FROM SITE AS DIRECTED. FOR NEW WORKS OR REINSTATEMENT WORKS REFER TO NOTE 1.
6. MINIMUM PIPE REQUIREMENTS UNDER ROAD PAVEMENTS AND TAKING ROAD RUNOFF TO BE 300mm DIA. RRJ R.C.



GREATER DANDENONG

PIPE LAYING DETAIL
FOR PIPES NOT UNDER ROAD PAVEMENT

LAST UPDATED – SEPTEMBER 2014

INFRASTRUCTURE PLANNING

SD 225–A