



NOTES

1. RESIDENTIAL DRAINAGE CONNECTIONS SHOULD BE 100mm DIA.
2. UNIT OR INDUSTRIAL DRAINAGE CONNECTIONS TO BE 150mm DIA.
3. PIPES AND FITTINGS TO BE U.P.V.C AND MEET AS 1260 CLASS SN8 (OR ALTERNATIVELY CLASS SN10)
4. ALL JOINTS TO BE SOLVENT WELDED WITH APPROVED SOLVENT.
5. WHERE EASEMENT DRAIN IS ON OPPOSITE SIDE OF BOUNDARY FENCE PRECAST CONCRETE INLET GRATE TO BE OFFSET ONE METRE FROM PROPERTY BOUNDARY
6. CONNECTION TO BE FLOWCON PREFABRICATED CONNECTION OR APPROVED EQUIVALENT

FOR USE:-

WHERE PROPERTY DRAINAGE AND EASEMENT DRAIN
VERTICAL SEPARATION IS LESS THAN 0.5 METRES.



GREATER DANDENONG

PROPERTY DRAIN CONNECTION

TYPE 1

LAST UPDATED - MARCH 2015

INFRASTRUCTURE PLANNING

SD 501-B