


2. UNIT OR INDUSTRIAL DRAINAGE CONNECTIONS TO BE 150mm DIA.
3. PIPES AND FITTINGS TO BE U.P.V.C., AND MEET AS 1260 CLASS SN8 (OR ALTERNATIVELY SN10)

### NOTES

1. ALL JOINTS TO BE SOLVENT WELDED WITH APPROVED SOLVENT.
2. HOUSE DRAIN TO BE MARKED ON SIDE OF THE FOOTPATH , WITH APPROVED STAMP.
3. END OF HOUSEDRAIN TO BE EXTENDED 500mm INTO PROPERTY AND TAPED OR CAPPED.
4. HOUSE DRAIN TO BE INSTALLED 5.0m FROM LOW SIDE OF BLOCK UNLESS SERVICES INTERFERE.
5. IN SITUATIONS WHERE THERE IS NO FOOTPATH, A PEG IS TO BE INSTALLED AT END OF HOUSEDRAIN.
6. HAUNCHING OF PIPE REQUIRED IF TRENCH INFERIOR.
7. WHERE PIPE NOT INSTALLED IN SINGLE LENGTH, APPROVED CONNECTORS MUST BE USED.



GREATER DANDENONG

PROPERTY DRAIN CONNECTION  
TYPE 7 – CONNECTION TO BARRIER TYPE KERB  
AND CHANNEL – NEW INSTALLATION

LAST UPDATED – MARCH 2015

INFRASTRUCTURE PLANNING

SD 507-B