



### NOTES

1. RESIDENTIAL DRAINAGE CONNECTIONS SHOULD BE 100mm DIA.
2. UNIT OR INDUSTRIAL DRAINAGE CONNECTIONS TO BE 150mm DIA.
3. PIPES AND FITTINGS TO BE U.P.V.C. TO MEET AS1260 CLASS SN8 (OR ALTERNATIVELY SN10)
4. ALL JOINTS TO BE SOLVENT WELDED WITH APPROVED SOLVENT.
5. CONNECTION TO BE FLOWCON PREFABRICATED CONNECTION OR APPROVED EQUIVALENT



**GREATER DANDENONG**

**PROPERTY DRAIN CONNECTION**

TYPE 3

LAST UPDATED - MARCH 2015

INFRASTRUCTURE PLANNING

**SD 503-B**