



TYPICAL CROSS SECTION

### NOTES

1. FOR RESIDENTIAL STREETS CONDUITS TO BE 40mm CLASS 12 PVC LAID BELOW THE PAVEMENT BED AT A GRADE OF 1 IN 100 FALLING TOWARD THE LOW SIDE OF THE STREET
2. FOR INDUSTRIAL ESTATES CONDUITS TO BE 200mm I.D. CLASS 12 PVC FOR WATER AND 100mm FOR GAS, LAID BELOW THE PAVEMENT BED AT A GRADE OF 1 IN 100 FALLING TOWARD THE LOW SIDE OF THE STREET
3. CONDUITS MUST EXTEND A MINIMUM OF 750mm BEYOND BACK OF KERB
4. CONDUIT TRENCH TO BE BACKFILLED TO SUBGRADE LEVEL WITH 20mm CLASS 3 CRUSHED ROCK
5. UNDER EXISTING PAVEMENTS CONDUITS MUST BE INSTALLED BY BORING, UNLESS OTHERWISE APPROVED.



GREATER DANDENONG

SERVICE CONDUIT LOCATION DETAILS  
FOR LOCAL ACCESS STREETS AND COLLECTOR ROADS

LAST UPDATED – SEPTEMBER 2014

INFRASTRUCTURE PLANNING

SD 009-B